

## CERTIFICATE OF ANALYSIS

### Asbestos Identification

Certificate No: 18-3663

<b>Client:</b>	Central Queensland University	<b>Date Sampled:</b>	2-07-2018
<b>Client Contact:</b>	Grant Farrell	<b>Date Received:</b>	3-07-2018
<b>Telephone:</b>	0407 760 770	<b>Date Analysed:</b>	3-07-2018
<b>Email:</b>	g.farrell@cqu.edu.au	<b>Order No.:</b>	CQU0088
<b>Address:</b>	Building 37 554, 700 Yaamba Road Norman Gardens QLD 4701	<b>Sampled By:</b>	As Received
<b>Site:</b>	ROK Building 19		

#### Test Method:

Qualitative identification of asbestos types in bulk samples at COHLABS Laboratory by polarised light microscopy, including dispersion staining techniques using COHLABS in-house method ID-1, AS4964 (2004). The results contained within this report relate only to the sample(s) submitted for testing. COHLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. This document may not be reproduced except in full.


Lab ID	Sample ID	Sample Details	Sample Type	Size / Weight cm/g	Asbestos Present	Fibres Identified
001	CQU0089	Bld 19, ground floor, fascia, north entrance, right side	Fibre Cement	5 x 2	No	NAD, ORF
002	CQU0090	Bld 19, level 3, fascia, east side fire exit	Fibre Cement	6 x 4	No	NAD, ORF
003	CQU0091	Bld 19, ground floor, south entrance, dome sheeting	Fibre Cement	4 x 2	No	NAD, ORF
004	CQU0092	Bld 19, level 3, balcony, soffit sheeting	Fibre Cement	8 x 8	No	NAD, ORF

#### Fibre Identification Legend

CHR	Chrysotile (white asbestos)	ORF	Organic Fibre
AMO	Amosite (Brown/Grey asbestos)	SMF	Synthetic Mineral Fibre
CRO	Crocidolite (Blue asbestos)	NFD	No Fibres Detected
UMF	Unknown Mineral Fibre	NAD	No Asbestos Detected


#### Approved Identifier

Name: Michael Shepherd



#### Approved Signatory

Name: Michael Shepherd



Samples are routinely disposed of approximately 1 month from receipt. Requests for longer term sample storage must be received in writing.



NATA Accreditation number: 19499

Accredited for compliance with ISO/IEC: 17025. The results of tests, calibrations, and or measurements included in this document are traceable to Australian/national standards.

ABN: 62 166 540 094